

NERC

NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

Efforts to Maintain Adequate Frequency Response

NERC Frequency Response Initiative



NAGF Annual Meeting
October 5, 2016

RELIABILITY | ACCOUNTABILITY




- Started in 2009
- Technical studies to support development of BAL-003-1
- 2012 Frequency Response Initiative Report – The Reliability Role of Frequency Response
 - Explained Frequency Response
 - Analyzed resource loss contingencies
 - Method to calculate Interconnection Frequency Response Obligations (IFROs)
 - Method to measure Frequency Response performance
 - Examined state of generation fleet governors
 - Called for NERC Frequency Response Resource Guideline to define the performance characteristics expected for supporting reliability
- Frequency Response Annual Analysis reports
- Ongoing analysis of frequency and frequency response

- Monitoring of ERS Measures
 - Long-Term Reliability Assessment
 - State of Reliability Report
- NERC-ERAG Assessment on Frequency Response in Eastern Interconnection – More discussions tomorrow
- ERSWG Development of Sufficiency Guidelines
- Expansion of NERC Reliability Guideline on Primary Frequency Control to include electronically-coupled resources
- Coordinating with IEEE on the frequency response requirements in their Standard 1547 for Distributed Energy Resources




****Dial positions are for discussion purposes****



Frequency Response Annual Analysis (FRAA)

Complete and Ongoing


- NERC System Analysis group develops an annual frequency response report for all interconnections.
- FRAA establishes the Interconnection Frequency Response Obligation (IFRO) and Balancing Authority Frequency Response Obligations (BA FRO).
- 2016 FRAA was approved by the Operating Committee in September 2016
- IFROs not changing for Operating Year 2017.



Regulatory Actions

Work in Progress


- Industry stakeholder group worked with NERC staff to develop comments for FERC NOI,
- Changes made to SGIA
- Possible changes to LGIA



Alert

Complete


- RS and FWG developed a NERC Advisory Alert on governor response.
- The advisory alert was published in January 2015 and addressed governor response and control coordination for synchronous generation.
- Webinars and industry outreach conducted
- Improvements should be measurable for each generator as well as the interconnection as a whole.



BAL-003

Work in Progress


- NERC Reliability Standard BAL-003 defines an Interconnection Frequency Response Obligation (IFRO) and subsequent Balancing Authority obligations to preserve reliability and ensure the frequency nadir for the largest credible event stays above UFLS.
- R2, R3, and R4 on Frequency Bias Settings in effect April 2016
- R1 on Frequency Response goes into effect December 2016 (Operating Year 2017)
- Refinements to BAL-003 may be needed in the future.



State of Reliability Report (SOR)

Inconclusive


- New measures to be included and considered for the 2016 report.
- 2016 report published in May
- The report addresses ERS and other ALR Metrics and the *FRM* for each event (*ALR 1-12 events*)
- Currently has not found supporting data that firmly identifies a decline in frequency response
- PAS will continue to analyze and support as necessary.



Long-Term Reliability Assessment (LTRA)

Work in Progress


- Key findings from past assessments indicated a trend of more asynchronous resources and retirements of conventional generation, potential decreasing the overall inertia and frequency response capability of the BPS.
- In 2016, the LTRA includes an evaluation of ERS measures.
- The 2016 LTRA will be published in December.
- Special Assessment to be conducted on frequency response and the changing resource mix in Eastern Interconnection.



Essential Reliability Services WG

Work in Progress

- The ERSWG has four measures relative to frequency for BA's and interconnections.
- These measures also include revised ALR 1-12 metric (now metric M4).
- The WG will monitor activities of the working groups related to ERS measures
- The ERSWG working on initial strategy on quantifying the sufficiency guidelines for the ERS measures.
- Whitepaper to be completed by December 2016.



RS/OC Guideline

Phase I Completed

- The RS and OC developed a guideline for generator owners on governor response and DCS control strategies for thermal plants.
- The guideline includes industry recommended governor deadband and droop settings that will potentially enable resources to provide better frequency response to the BPS
- The OC approved the guideline in December 2015
- Being revised to add asynchronous resources (per Recommendation 1 of 2012 Frequency Response Initiative report)

Add Inverter-based resources

- Inverter-based resources can be very fast (too fast?)
 - Inverter-base resource speed is based on the time constants and speed of the resource behind the inverter
 - Extremely fast action can cause instability of the plant or the system
 - Interaction of multiple inverters at high speed can cause problems

Address non-traditional FR resources

- Storage (stationary) charging device behavior
- Storage can operate in several modes
- Demand response used as for Frequency Response
- “Modulated Load”

Frequency Response Requirements: Different Approaches and Considerations

Not Required in Interconnection Agreement

Relies on third-party/market mechanisms to meet requirements

- Requirement would apply to BAs; no requirement for GOs to have **capability**
- No measurable performance for GOs; only Interconnection and BA FRMs
- No requirements on deadbands – GOs can set however they like
- Wider frequency variability – status quo
- No requirements on droop – GOs can set however they like
- Tendency to depend on “select few” resources to meet BA FRO – what if offline?
- May drive stability risks for unbalanced response – heavy transfers on inerties
- BA approach is unique to North America

Required for All Resources

Interconnection Requirement/Rule/Reliability Standard for frequency responsive resources

- Requirement would apply to all applicable GOs – “fair and equitable” **capability**
- Measurable performance for GOs
- Requirement for reasonable deadbands in support of frequency stability
- Projected (seen in ERCOT) tighter control
- Requirement for reasonable droop controls in support of frequency stability
- Wholesome reliance on all resources – units always online
- Operator flexibility
- Uniform response alleviates inertia pickups
- Similar to most modern systems’ Grid Codes

- Primary Frequency response (as part of overall frequency support) is an Essential Reliability Service (ERS).
- Essential for interconnection stability, prevention of equipment damage, coordination of droop response, and system restoration (cranking path).
- The ERSTF final report recommended that *all* resources have the *capability* to provide frequency response.


Changing Resource Mix

- Potential for lower inertia with retirement of coal and oil-fired synchronous generators
- Higher penetration of renewables with potentially lower frequency response
- No assurance of adequate inertia or frequency response capability for some resource dispatch scenarios



Conservative approach

- All resources should have frequency responsive capability to assure that frequency response is available for any resource dispatch.

Frequency Response Basics




Frequency Response Breakdown




- Traditional generation
- Wind Turbines
 - “Synthetic Inertia”
 - Off-optimal blade attack angle – backing down from maximum
- Distributed Energy Resources
 - Solar
 - Micro turbines
 - Micro grid resources
- Load acting as a resource
 - Tripped by specialized under-frequency relays
 - Smart appliances – independent operation
 - Aggregated load – controlled by aggregator
 - “Modulated load”


Frequency Response Control Continuum



Importance of System Inertia in ERCOT




Inertia (GW-second): 1 > 2 > 3



— Event with 837 MW Trip (March, 2010) ERCOT Load was 23655 MW with 27,499 MW of total Conventional Generation
 — Event with 890 MW Trip (July, 2009) ERCOT Load was 49,209 MW with 55,609 MW of total Conventional Generation


Trade-off between Inertia and Primary Frequency Response



Primary Frequency Response (MW): 3 > 2 > 1


- High-speed energy injection following loss of resources
 - High-speed response during Arresting Phase of a Frequency Event
 - Response proportional to the change in frequency and rate of change in frequency
 - Help to offset loss of system inertia due to displacement or retirement of generation
- Continuous proportional response to frequency deviations
 - Frequency control services
- Energy injection to perform ramping services
 - Reduce severity of solar-based resource drop-off in evening

**Load, Wind & Solar Profiles --- Base Scenario
January 2020**



CAISO Net Load Pattern Changes

CAISO Net Load --- 2012 through 2020




- Supplement generation during severe upward ramps
 - Morning load pick-up before solar reaches full output
 - Evening load pick-up when solar output is dropping off
- Absorb energy during downward ramps
 - When solar and wind output ramps up to full output and morning load stabilizes
- Absorb energy to prevent over-generation
 - Charge storage when solar and wind output exceeds energy demand
- Load-following to provide balance for variable resources
 - Wind and solar variability due to changes in weather



Changing Frequency Profile


Frequency Probability Density Function by Interconnection



- Only ERCOT has a frequency response performance requirement –BAL-001-TRE-1
 - Also requires 17 (16.67) mHz deadband*, 4 to 5% droop, and proportional, non-step response
- Québec system requirements
 - No deadband allowed
 - 5% droop on all units
- Eastern and Western – NERC Reliability Guideline on Primary Frequency Control (December 2015) calls for:
 - ± 36 mHz deadband
 - 3 to 5% droop

* Except for steam and hydro turbines with mechanical governors – ± 34 mHz

ERCOT Frequency Probability Density Function Changes




Exposing a single 600 MW generator to ERCOT 2008 and 2015 frequency profiles with typical settings:

- 2008 – 5% Droop, ± 36 mHz deadband, “Step” response
 - 622,574 MW-minutes of Primary Frequency Control.
- 2015 – 5% Droop, ± 17 mHz deadband, “Proportional” response
 - 211,215.8 MW-minutes of Primary Frequency Control.
- 68.12% (451,358.2 MW-minute) *DECREASE* in generator control action by the governor in 2015 compared to 2008 even with the lower dead-band setting.

600 MW Unit Response – 2008 36 mHz Deadband versus 2015 17 mHz Deadband

January through December of Each Year





Questions and Answers